

M/S : PERBADANAN PRODUKTIVITI MALAYSIA (MPC)

PETI SURAT 64,JALAN SULTAN ,
46900 PETALING JAYA SELANGOR.

ATTN : Account Department.

INVOICEInvoice No : **MTK - 004012**Date : 25TH AUGUST 2021

ORDER NO.	DATE DELIVERED/ D.O	OUR REFERENCE/ JOB SHEET	TERMS
034216-00	25- 08 - 2021	REFER SERVICE REPORT	CASH
RE : TO SERVICE AND MAINTENANCE OF FIRE PROTECTION SYSTEM AT BANGUNAN MPC, JALAN SULTAN PETALING JAYA , JULY AND AUGUST 2021.			

Being work completed for the servicing and maintenance of the following system:-

FIRE PROTECTION SYSTEM FOR **BLOCK INOVASI & BLOCK PRODUCTIVITY** :

1. FIRE ALARM SYSTEM.
2. HOSE REEL SYSTEM.
3. TOTAL FLOODING Co2 SYSTEM - Switch Room.
4. SERVER ROOM - INERTEC 100 GAS SYSTEM.
5. SERVER ROOM- BLOCK B.

For the total sum of :Rm 1,000.00Thank you,
Yours Faithfully,
Impak Engineering.

(MOHD TAIB BIN KATAP)

Saya memperakui bahawa barang
berserta perkhidmatan yang dipesan
telah dilaksanakan dengan memuaskan
dan sempurna.Tayau Amirul Qamar Zakaria
No. Penolong Jurutera (JA28)
Jabatan Perbadanan Produktiviti Malaysia (MPC)
Tarikh: 27/8/21



IMPAK ENGINEERING

(002022780-K)

NO 61 JALAN TELIPOT 2C BS 9, KAWASAN PERINDUSTRIAN BUKIT SENTOSA 3,
48300 RAWANG SELANGOR.

TEL NO : 019 278 5475, FAX : 03 6021 5475, E-mail : ipkrich1@gmail.com

FIELD SERVICE AND MAINTENANCE REPORT

Name of Customer / Site : M. PCSER REPORT NO : 2111Address : 111 Sultan, P.J.

Contact : _____ Phone : _____

DATE : 25/8/2021TYPE OF JOB SYSTEM : Warranty / T&C ☐ Servicing ☒ On Call ☐ Emergency ☐ Repair ☐

CHECKLIST <u>BK C</u>	CHECKLIST <u>BK C</u>	CHECKLIST																								
A FIRE ALARM SYSTEM - AC Supply (240V) ☒ - DC Unit (24V) ☒ - AC/DC Auto-Switching ☒ - Battery Condition ☒ - Zone Selector Switch ☒ - Bulb Indicators ☒ - AHU Trips ☒ - Fire Brigade Connection/ CMS ☒ - Lift Sensors ☒ - Heat / Smoke Detector ☒ - Manual Breakglass ☒ - Alarm Circuitry ☒ - Evacuation Switch ☒ - Bell and Buzzer ☒ - Pump Indication ☒ - Gas Indication ☒	B HOSE REEL SYSTEM - Pumpsets Control Panel ☒ - Electrical Components ☒ - Phase Indicators ☒ - Battery Condition ☒ - Motor Components ☒ - Pump Seal and Coupling ☒ - Diesel Pumpsets Teat ☒ - Diesel Engine Components ☒ - Water Tank and Indicator ☒ - Low Level Indicator and Motoring Signal ☒ - Valves and Fittings ☒ - Drum, Rubber Hose and Nozzle ☒ - Pumpsets Test ☒ - Pumpsets Pressure Settings ☒ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Duty			Standby			E GAS / CO2 SYSTEM - AC Supply (240V) ☐ - DC Unit (24V) ☐ - AC/DC Auto-Switching ☐ - Battery Condition ☐ - Zone Selector Switch ☐ - Bulb Indicators ☐ - Gas Discharge and Isolation Switch ☐ - Gas Discharge Delay Timer ☐ - Manual Key Switch ☐ - Heat / Smoke Detector ☐ - Curtain and Exhaust Fan Cut-off ☐ - Nozzle, Valves and Fitting ☐ - Pressure Gauge ☐															
	cut in	cut out																								
Duty																										
Standby																										
C SPRINKLER SYSTEM - Pumpsets Control Panel ☐ - Electrical Components ☐ - Phase Indicators ☐ - Battery Condition ☐ - Motor Components ☐ - Pump Seal and Coupling ☐ - Diesel Pumpsets Test ☐ - Diesel Engine Components ☐ - Water Tank and Indicator ☐ - Low Level Indicator and Monitoring Signal ☐ - Valves and Fitting ☐ - Sprinkler Heads ☐ - Sprinkler Pump Flow Test ☐ - Pumpsets Test ☐ - Pumpsets Pressure Settings ☐ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Jockey</td> <td></td> <td></td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Jockey			Duty			Standby			D WET RISER AND HYDRANT SYSTEM - Pumpsets Control Panel ☐ - Electrical Components ☐ - Phase Indicators ☐ - Battery Condition ☐ - Motor Components ☐ - Pump Seal and Coupling ☐ - Diesel Pumpsets Test ☐ - Diesel Engine Components ☐ - Water Tank and Indicator ☐ - Low Level Indicator and Monitoring Signal ☐ - Valves and Fittings ☐ - Hydrant Equipment and Components ☐ - Landing Valve and Components ☐ - Pumpsets Teat ☐ - Pumpsets Pressure Settings ☐ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Jockey</td> <td></td> <td></td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Jockey			Duty			Standby			F FIREMAN INTERCOM - AC Supply (240V) ☐ - DC Unit (24V) ☐ - AC/DC Auto-Switching ☐ - Battery Condition ☐ - Zone Control Unit ☐ - Bulb Indicators ☐ - Master Control Unit ☐ - Buzzer Cut-Off ☐ - Audible Buzzer And Flashing Indicator ☐
	cut in	cut out																								
Jockey																										
Duty																										
Standby																										
	cut in	cut out																								
Jockey																										
Duty																										
Standby																										
		G PUBLIC ADDRESS AND SOUND SYSTEM - AC Supply (240V) ☐ - Battery Condition ☐ - Battery Charger ☐ - AC/DC Auto-switching ☐ - Zone Selector Switch ☐ - Station Call Switches ☐ - Emergency Paging Switches ☐ - Amplifier Test ☐ - Microphone Test ☐ - Ceiling and Wall Speakers ☐																								

Remarks : DAMP, wiring started, need to rectify.Service Attended By : [Signature]

Signed : _____

Saya memperakui bahawa barang
barang/perkhidmatan yang dipesan
telah dilaksanakan dengan memuaskan
dan sempurna.

Customer Certification:

Amirul Qamar Zakaria
Penolong Jurutera (JAB)
Perbadanan Produktiviti Malaysia (MPC)
Jabatan
Tanjong

Chop & Signed : _____
Tanjong



IMPAK ENGINEERING

(002022780-K)

NO 61 JALAN TELIPOT 2C BS 9, KAWASAN PERINDUSTRIAN BUKIT SENTOSA 3, 48300 RAWANG SELANGOR.

TEL NO : 019 278 5475, FAX : 03 6021 5475, E-mail : ipkrich1@gmail.com

FIELD SERVICE AND MAINTENANCE REPORT

Name of Customer / Site : M.P.C.SER REPORT NO : **2110**Address : On Cufu, P.S.

Contact : _____ Phone : _____

DATE : 25/8/2021TYPE OF JOB SYSTEM : Warranty / T&C ☐ Servicing ☒ On Call ☐ Emergency ☐ Repair ☐

CHECKLIST <u>Blok E.</u>	CHECKLIST <u>Blok E.</u>	CHECKLIST																								
A FIRE ALARM SYSTEM - AC Supply (240V) ☒ - DC Unit (24V) ☒ - AC/DC Auto-Switching ☒ - Battery Condition ☒ - Zone Selector Switch ☒ - Bulb Indicators ☒ - AHU Trips ☒ - Fire Brigade Connection/ CMS ☒ - Lift Sensors ☒ - Heat / Smoke Detector ☒ - Manual Breakglass ☒ - Alarm Circuitry ☒ - Evacuation Switch ☒ - Bell and Buzzer ☒ - Pump Indication ☒ - Gas Indication ☒	B HOSE REEL SYSTEM - Pumpsets Control Panel ☒ - Electrical Components ☒ - Phase Indicators ☒ - Battery Condition ☒ - Motor Components ☒ - Pump Seal and Coupling ☒ - Diesel Pumpsets Teat ☒ - Diesel Engine Components ☒ - Water Tank and Indicator ☒ - Low Level Indicator and Motoring Signal ☒ - Valves and Fittings ☒ - Drum, Rubber Hose and Nozzle ☒ - Pumpsets Test ☒ - Pumpsets Pressure Settings ☒ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Duty			Standby			E GAS / CO2 SYSTEM - AC Supply (240V) ☐ - DC Unit (24V) ☐ - AC/DC Auto-Switching ☐ - Battery Condition ☐ - Zone Selector Switch ☐ - Bulb Indicators ☐ - Gas Discharge and Isolation Switch ☐ - Gas Discharge Delay Timer ☐ - Manual Key Switch ☐ - Heat / Smoke Detector ☐ - Curtain and Exhaust Fan Cut-off ☐ - Nozzle, Valves and Fitting ☐ - Pressure Gauge ☐															
	cut in	cut out																								
Duty																										
Standby																										
C SPRINKLER SYSTEM - Pumpsets Control Panel ☐ - Electrical Components ☐ - Phase Indicators ☐ - Battery Condition ☐ - Motor Components ☐ - Pump Seal and Coupling ☐ - Diesel Pumpsets Test ☐ - Diesel Engine Components ☐ - Water Tank and Indicator ☐ - Low Level Indicator and Monitoring Signal ☐ - Valves and Fitting ☐ - Sprinkler Heads ☐ - Spinkler Pump Flow Test ☐ - Pumpsets Test ☐ - Pumpsets Pressure Settings ☐ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Jockey</td> <td></td> <td></td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Jockey			Duty			Standby			D WET RISER AND HYDRANT SYSTEM - Pumpsets Control Panel ☐ - Electrical Components ☐ - Phase Indicators ☐ - Battery Condition ☐ - Motor Components ☐ - Pump Seal and Coupling ☐ - Diesel Pumpsets Teat ☐ - Diesel Engine Components ☐ - Water Tank and Indicator ☐ - Low Level Indicator and Motoring Signal ☐ - Valves and Fittings ☐ - Hydrant Equipment and Components ☐ - Landing Valve and Components ☐ - Pumpsets Teat ☐ - Pumpsets Pressure Settings ☐ <table border="1"> <tr> <td></td> <td>cut in</td> <td>cut out</td> </tr> <tr> <td>Jockey</td> <td></td> <td></td> </tr> <tr> <td>Duty</td> <td></td> <td></td> </tr> <tr> <td>Standby</td> <td></td> <td></td> </tr> </table>		cut in	cut out	Jockey			Duty			Standby			F FIREMAN INTERCOM - AC Supply (240V) ☐ - DC Unit (24V) ☐ - AC/DC Auto-Switching ☐ - Battery Condition ☐ - Zone Control Unit ☐ - Bulb Indicators ☐ - Master Control Unit ☐ - Buzzer Cut-Off ☐ - Audible Buzzer And Flashing Indicator ☐
	cut in	cut out																								
Jockey																										
Duty																										
Standby																										
	cut in	cut out																								
Jockey																										
Duty																										
Standby																										
		G PUBLIC ADDRESS AND SOUND SYSTEM - AC Supply (240V) ☐ - Battery Condition ☐ - Battery Charger ☐ - AC/DC Auto-switching ☐ - Zone Selector Switch ☐ - Station Call Switches ☐ - Emergency Paging Switches ☐ - Amplifier Test ☐ - Microphone Test ☐ - Ceiling and Wall Speakers ☐																								

Remarks : D zone 1 fault indicate due to wiring disconnect at CMC (renovation route) need to rectify.D Diesel engine, cannot run due to starter panel fault, need to rectify

Service Attended By : _____

Signed _____

Saya memperakui bahawa barang
barang/perkhidmatan yang dipesan
telah dilaksanakan dengan memuaskan
Customer.

Amirul Daman Zakaria
Tandapan Ahmad Fauzi
Bendahara Juruera (JAZR)
Nama Penerimaan Projek (Nama Projek)
Tarikh: 27/8/21



IMPAK ENGINEERING

(002022780-K)

NO 63 JALAN KEMBOJA 4C/4 BUKIT SENTOSA 3, 48300 RAWANG SELANGOR.

TEL NO : 019 278 5475, FAX : 03 6021 5475, E-mail : ipkrich1@gmail.com

FIELD SERVICE AND MAINTENANCE REPORT

Name of Customer / Site : M.P.C.REPORT NO : 1692Address : 11n Sultan, P.O.DATE : 25/8/2021TYPE OF JOB SYSTEM : Warranty / T&C ☐ Servicing ☒ On Call ☐ Emergency ☐ Repair ☐

FIXED INSTALLATION SYSTEMS CHECKLIST

C02 ☐ ARGONITE ☐ OTHERS: Blk E Blk B Blk B

ITEM	LOCATION	Blk E M-SB Room.	Blk B Server Room	Blk B Server Room.			
1. AC Supply (230V)		✓	✓	✓			
2. DC Unit (24V)		✓	✓	✓			
3. AC/DC Auto-Switching		✓	✓	✓			
4. Battery Condition		Faulty	✓	Repair			
5. Zone Selector Switch		✓	✓	✓			
6. Bulb Indicators		✓	✓	✓			
7. Gas Discharge and Isolation Switch		✓	✓	✓			
8. Gas Discharge Delay Timer	In room	✓	✓	✓			
9. Manual Key Switch		✓	✓	✓			
10. Heat / Smoke Detector		✓	✓	✓			
11. Curtain and Exhaust Fan Cut-off		n/a	✓	n/a			
12. Nozzle, Valves and Fitting		✓	✓	✓			
13. Pressure Gauge		n/a	✓	✓			

Remarks / Recommendation : 1) Battery charger card faulty at M-SB room Blk E & server room Blk B.Service Attended By : [Signature]

Signed

Saya mempercayai bahawa barang
barang/perkhidmatan yang diberikan
telah dilaksanakan dengan memuaskan
dan saya mengesahkan

Customer Certification

Amirul Qamar Zakaria

Tandatangan: [Signature]Pendaftaran: JA29Nama: Perbadanan Produktiviti Malaysia (MPC)Jawatan: Chop & SignedTarikh: 27/8/21